ADDENDUM NO. 1

PROJECT MANUAL

WAUNAKEE UTILITIES WAUNAKEE, WISCONSIN WELL NO. 6 WELL FACILITY CONTRACT 4-2025

Bids will be received until November 18, 2025, at 1 P.M., local time.

This Addendum to the Project Manual is issued to modify, explain, or correct the original Project Manual and is hereby made part of the Contract Documents.

A. SPECIFICATIONS

- 1. DIVISION 23-HEATING, VENTILATING, AND AIR CONDITIONING
 - a. Page 23 23 00-3, SECTION 23 23 00-REFRIGERANT PIPING, PART 2-PRODUCTS, 2.03.A.

ADD the following new paragraph after Paragraph 2.03.A:

- "B. R-454B: Difluoromethane/tetrafluoropropene is an acceptable refrigerant alternative to R-32."
- b. Page 23 81 26-3, SECTION 23 81 26-SPLIT-SYSTEM AIR CONDITIONERS, PART 2-PRODUCTS, 2.01.D.1.

ADD "or R-454B" after "R-32" in Paragraph 2.01.D.1.

- 2. DIVISION 33-UTILITIES
 - a. Page 33 11 34-4, SECTION 33 11 34-DEEP WELL TURBINE PUMP, <u>PART 2-PRODUCTS</u>, 2.03.E.1.

CHANGE "10 inches nominal diameter" to "8-inch nominal diameter" in Paragraph 2.03.E.1.

B. DRAWINGS

1. SHEET NO. 13-LANDSCAPE PLAN

REPLACE Sheet No. 13 with the attached revised Sheet No. 13.

Dated at Madison, Wisconsin November 13, 2025

MICHAELJ *
FORSLUND
E-37315
MADISON
WI
SSIONAL FINANCIAL

STRAND ASSOCIATES, INC.® 910 West Wingra Drive Madison, WI 53715

